

Electrocell Savings Validation and Case Study for Massachusetts Pharmaceutical Company



Energy Efficiency & Sustainability

Ways of Working SpC Engineering – Key Initiatives for 2022

Key attributes of energy improvements at sites

- Maintain constant communication with site EMs tracking progress
- Implement Energy Management System (EnMS) and ISO 50k
- Virtually attend ISO 50k audits, communicate findings with other sites
- Continue to promote L3 digital fault diagnostics where applicable
- Continue to promote new technology pilots at sites for scale-up 2022-2024 sustainability projects (ex: Electrocells, UVC, solar heating, solar voltaic, heat recovery chillers, heat pumps, carbon capture)

Energy efficiency on new investment projects at sites

- Complete sustainability energy assessments for new projects >1M€
- Consider new technologies for implementation (deviate from norm)
- Ensure adequate building controls are in place for L3 digital fault diagnostics (Cimetrics Analytika)
- Complete energy models where applicable on larger projects to understand consumption and cost requirements
- Leverage Framingham Energy Pilot (B2022) over the SpC network



Energy Efficiency & Sustainability

What is an Electrocell?

An Electrocell system is an electrostatic precipitator which removes particles from open condenser cooling tower water streams down to 1 micron. This low maintenance piece of equipment cleans the water through electrolysis versus using sand filtration which uses significant pumping energy. The unit cleans the water so clean there is no longer build up of debris on the inside of the chiller tubes. Introducing an electromagnetic field to water changes the surface tension of the water resulting in better heat transfer.

Energy Savings

Because the condenser water is so clean from this process, cleaning chiller tubes is no longer necessary. When chiller tubes are clean, heat transfer is increased resulting in a higher coefficient of performance, the result is energy savings.

Water & Chemical Savings

There are chemical and water savings as well. Large amounts of chemicals used to suspend solids in the condenser water and flush them out with city water is no longer needed. Chemicals are still required for conductivity and biocidal control. The result is a significant reduction in water and chemical consumption.

Carbon Emissions Savings



Higher chiller efficiency (coefficient of performance) and reduced pumping power results in less kilowatts consumed. Less kilowatts = **Less carbon emissions!**



Energy Efficiency & Sustainability

Overview of Technology

Installation Drawings



KEY NOTES



- CONNECT NEW 2" GLASSING CELL SUPPLY PIPING TO EXISTING 24" OHS HEADERS/PROVIDE 2" SET OF CONNECTIONS AT THE BOTTOM OF PIPING.
- MEET TOP AND PIPING MATERIAL SHALL BE ASTM A53 SCHEDULE 40 PIPE.
- CONNECT NEW 2" GLASSING CELL RETURN PIPING TO EXISTING 24" OHS HEADERS. PROVIDE 2" SET OF CONNECTIONS AT THE TOP SIDE OF PIPING. MET TOP AND PIPING MATERIAL SHALL BE ASTM A53 SCHEDULE 40 PIPE.
- 2" SUPPLY AND RETURN PIPING FROM TROUGH CHILLER ROOM ROOF RUN BEING ALONG CEILING TO ELECTRIC CELL SYSTEM SKID. ROOF PIPING PENETRATIONS SHALL CONFORM TO THE OTHERS BEING INSTALLED. PROVIDE 1 1/2" THICK INSULATION PAD UNDER SKID AND SECURE SKID TO CHILLER ROOM FLOOR. REFER TO MANUFACTURERS SUBMITTAL FOR PHYSICAL DIMENSIONS, DATA AND PIPING CONNECTION LOCATIONS.
- THE PHYSICAL DISTANCE BETWEEN THE NEW SUPPLY AND RETURN IN-H LOCATIONS SHALL BE A MINIMUM OF 8'-0" AWAY. FIELD NOTES EXIST IN-H LOCATIONS.

MECHANICAL CONSTRUCTION NOTES

- PROVIDE 1-1/2" THICK INSULATION WITH ALUMINUM FACED ON ALL EXPOSED ROOFING AND ALL EXPOSED SURFACES TO WHICH MECHANICAL CONSTRUCTION PENETRATIONS ARE MADE. INSULATION SHALL BE MEET TO THE MECHANICAL CONSTRUCTION PENETRATIONS AND THROUGH PENETRATIONS. SEE MECHANICAL CONSTRUCTION PENETRATIONS FOR MORE DETAILS.
- PROVIDE TWO SETS ISOLATION VALVES WITH MANUAL DRAIN LESS ON THE NEW TROUGH CHILLER AND THE OTHER AT THE SKID.
- ALL EXISTING MECHANICAL PIPING, EQUIPMENT AND ASSOCIATED DEVICES TO REMAIN UNLESS OTHERWISE NOTED.
- ALL NEW SUPPLY AND RETURN PIPING SHALL BE 24" OHS HEADERS/PROVIDE 2" SET OF CONNECTIONS AT THE BOTTOM OF PIPING. MEET TOP AND PIPING MATERIAL SHALL BE ASTM A53 SCHEDULE 40 PIPE.
- 2" SUPPLY AND RETURN PIPING FROM TROUGH CHILLER ROOM ROOF RUN BEING ALONG CEILING TO ELECTRIC CELL SYSTEM SKID. ROOF PIPING PENETRATIONS SHALL CONFORM TO THE OTHERS BEING INSTALLED. PROVIDE 1 1/2" THICK INSULATION PAD UNDER SKID AND SECURE SKID TO CHILLER ROOM FLOOR. REFER TO MANUFACTURERS SUBMITTAL FOR PHYSICAL DIMENSIONS, DATA AND PIPING CONNECTION LOCATIONS.
- THE PHYSICAL DISTANCE BETWEEN THE NEW SUPPLY AND RETURN IN-H LOCATIONS SHALL BE A MINIMUM OF 8'-0" AWAY. FIELD NOTES EXIST IN-H LOCATIONS.
- IF ANY MECHANICAL PIPING, EQUIPMENT AND ASSOCIATED DEVICES TO REMAIN UNLESS OTHERWISE NOTED.
- ALL NEW SUPPLY AND RETURN PIPING SHALL BE 24" OHS HEADERS/PROVIDE 2" SET OF CONNECTIONS AT THE BOTTOM OF PIPING. MEET TOP AND PIPING MATERIAL SHALL BE ASTM A53 SCHEDULE 40 PIPE.
- 2" SUPPLY AND RETURN PIPING FROM TROUGH CHILLER ROOM ROOF RUN BEING ALONG CEILING TO ELECTRIC CELL SYSTEM SKID. ROOF PIPING PENETRATIONS SHALL CONFORM TO THE OTHERS BEING INSTALLED. PROVIDE 1 1/2" THICK INSULATION PAD UNDER SKID AND SECURE SKID TO CHILLER ROOM FLOOR. REFER TO MANUFACTURERS SUBMITTAL FOR PHYSICAL DIMENSIONS, DATA AND PIPING CONNECTION LOCATIONS.
- THE PHYSICAL DISTANCE BETWEEN THE NEW SUPPLY AND RETURN IN-H LOCATIONS SHALL BE A MINIMUM OF 8'-0" AWAY. FIELD NOTES EXIST IN-H LOCATIONS.
- IF ANY MECHANICAL PIPING, EQUIPMENT AND ASSOCIATED DEVICES TO REMAIN UNLESS OTHERWISE NOTED.
- ALL NEW SUPPLY AND RETURN PIPING SHALL BE 24" OHS HEADERS/PROVIDE 2" SET OF CONNECTIONS AT THE BOTTOM OF PIPING. MEET TOP AND PIPING MATERIAL SHALL BE ASTM A53 SCHEDULE 40 PIPE.
- 2" SUPPLY AND RETURN PIPING FROM TROUGH CHILLER ROOM ROOF RUN BEING ALONG CEILING TO ELECTRIC CELL SYSTEM SKID. ROOF PIPING PENETRATIONS SHALL CONFORM TO THE OTHERS BEING INSTALLED. PROVIDE 1 1/2" THICK INSULATION PAD UNDER SKID AND SECURE SKID TO CHILLER ROOM FLOOR. REFER TO MANUFACTURERS SUBMITTAL FOR PHYSICAL DIMENSIONS, DATA AND PIPING CONNECTION LOCATIONS.
- THE PHYSICAL DISTANCE BETWEEN THE NEW SUPPLY AND RETURN IN-H LOCATIONS SHALL BE A MINIMUM OF 8'-0" AWAY. FIELD NOTES EXIST IN-H LOCATIONS.
- IF ANY MECHANICAL PIPING, EQUIPMENT AND ASSOCIATED DEVICES TO REMAIN UNLESS OTHERWISE NOTED.

NOM. SIZE	1/2"	3/4"	1"	1-1/4"	1-1/2"	2"	2-1/2"	3"	4"	6"
PIPE	7	7	7	8	10	11	12	14	14	14
TUBING	5	7	8	7	8	9	10	12	12	14

NOTE: FOR THROUGH HANGER TAKE SPACING OF SMALL SIZE ON TRAVEL.



MTE ENGINEERING
3048 LAKEWOOD BOULEVARD
WEST WOOD, MA 03099
781.321.7500



SA
70' N
FRAN

Project:
Drawn by: MMT
Checked by: TMM
Date: 8/5/2020
Scale:

CHILLER
PLANT
PART PLANS

M-1

Energy Efficiency & Sustainability

Pilot of Electrocell Units

Electrocell Installation



EC-6000 as installed



Electrostatic rod removed
for cleaning



Visually "clear"
condenser water



Particulate removed
from Condenser
water after 24-hours
with ElectroCell

Energy Efficiency & Sustainability

Validated Energy and Water Savings Results of Installed Electrocell Units

Summary of Savings

Chiller Plant	Compressor Demand Reduction (kW/ton)	Compressor Demand Reduction (percent)	Avg Monthly Reduction (kW)	Annual Electric Savings (MWh)	Annual Energy Savings (USD)	Water savings (kGal)	Annual Water Savings (USD)	Total Savings
55 NYA	0.08 ^a	13.9%	65	569	\$76k	1275	\$21k	\$97k
70 NYA	0.12 ^b	14.6%	126	1100	\$148k	2061	\$34k	\$181k
		Total	191	1673	\$224k	3336	\$55k	\$279k

Not included are chemical water treatment and reduced maintenance savings.

Utility Rates

	Water	Energy	Demand
Oct-May	\$16.38/kGal	\$0.086/kWh	\$29/kW
June-Sept	\$16.38/kGal	\$0.086/kWh	\$39/kW

a – compressor demand reduction analysis completed by Cimetrics, kWh and water savings by EMA.

b – compressor demand reduction, kWh, and water savings completed by EMA.



Local utility incentive up to 50% of the Project Cost

Annual savings = \$279k (Rebate \$489k project cost/2=\$244k) \$489k-\$244k = \$245k cost

10.5 Months Payback and 375 MTCO2 Annual Carbon Reduction !

Energy Efficiency & Sustainability

Investment Performance Summary

Project Totals for 55 + 70 Electrocell Installation

Total Project Kwh Savings	1,161,487
Total NPV (at 4.5%)	\$2,083,410
Total Investment	-\$489,110
Average IRR (<i>two installations</i>)	51.6%

Importantly Noted: These numbers do not include the escalation of energy and water costs over the 15 year life cycle so actual savings realized will be significantly higher over time.

The same would apply to chemical treatment savings.





Massachusetts Pharmaceutical Company

Sampling Source: Cooling Tower Basin Water (55NYA)

Electro Cell System: **XCell-4000 Particle Precipitator**



95.8%
particle
reduction
after
7.8 weeks

TEST METHOD: All tests completed by independent third-party laboratory. Samples analyzed by electro-optical particle analyzer employing the light scattering principle of operation with filtered water and particle data corrected. Stirring was continuous.

BASELINE SAMPLE -
Prior to ElectroCell Start-up - 22-OCT-2020

AFTER 7.8 WEEKS
with ElectroCell System - 16-DEC-2020

**PARTICLE COUNTS PER 100mL
TEST PORTION**

**PARTICLE COUNTS PER 100mL
TEST PORTION**

1 - 3 micron:	425,460
3 - 5 micron:	86,160
5 - 10 micron:	104,600
10 - 15 micron:	40,680
15 - 25 micron:	43,500
Over 25 micron:	<u>31,600</u>
TOTAL / 100mL:	732,000

1 - 3 micron:	396,835
3 - 5 micron:	79,229
5 - 10 micron:	46,577
10 - 15 micron:	7,926
15 - 25 micron:	4,693
Over 25 micron:	<u>1,267</u>
TOTAL / 100mL:	536,527

**SOLIDS PER 100 LITERS
OF SYSTEM VOLUME (mm³)**

**SOLIDS PER 100 LITERS
OF SYSTEM VOLUME (mm³)**

1 - 5 micron:	8.92
5 - 10 micron:	44.14
Over 10 micron:	<u>21,525.48</u>
TOTAL / 100 Liters:	21,578.54

216 ppm

1 - 5 micron:	8.25
5 - 10 micron:	19.66
Over 10 micron:	<u>887.88</u>
TOTAL / 100 Liters:	915.79

9 ppm

Electro Cell Systems

3320 Nazareth Road, Easton, PA 18045

Phn: (800) 949-3445 Fax: (610) 438-4472 email: info@electrocellsystems.com



PARTICLE ANALYSIS REPORT

Massachusetts Pharmaceutical Company

Sampling Source: Cooling Tower Basin Water (70NYA)

Electro Cell System: XCell-6000 Particle Precipitator



99.84%
particle
reduction
after
4 weeks

TEST METHOD: All tests completed by independent third-party laboratory. Samples analyzed by electro-optical particle analyzer employing the light scattering principle of operation with filtered water and particle data corrected. Stirring was continuous.

BASELINE SAMPLE -
Prior to ElectroCell Start-up - 16-DEC-2020

AFTER 4 WEEKS
with ElectroCell System - 13-JAN-2021

**PARTICLE COUNTS PER 100mL
TEST PORTION**

**PARTICLE COUNTS PER 100mL
TEST PORTION**

1 - 3 micron:	14,273,000
3 - 5 micron:	2,807,400
5 - 10 micron:	3,861,200
10 - 15 micron:	2,579,000
15 - 25 micron:	2,707,800
Over 25 micron:	<u>3,403,400</u>
TOTAL / 100mL:	29,631,800

1 - 3 micron:	58,381
3 - 5 micron:	15,738
5 - 10 micron:	12,842
10 - 15 micron:	4,219
15 - 25 micron:	4,972
Over 25 micron:	<u>5,359</u>
TOTAL / 100mL:	101,511

**SOLIDS PER 100 LITERS
OF SYSTEM VOLUME (mm³)**

**SOLIDS PER 100 LITERS
OF SYSTEM VOLUME (mm³)**

1 - 5 micron:	293.86
5 - 10 micron:	1,629.43
Over 10 micron:	<u>2,302,178.61</u>
TOTAL / 100 Liters:	2,304,101.90

23041 ppm

1 - 5 micron:	1.47
5 - 10 micron:	5.42
Over 10 micron:	<u>3,630.71</u>
TOTAL / 100 Liters:	3,637.60

36 ppm

Electro Cell Systems

3320 Nazareth Road, Easton, PA 18045

Phn: (800) 949-3445 Fax: (610) 438-4472 email: info@electrocellsystems.com

Energy Efficiency & Sustainability

Third Party Energy Savings Validation for Utility

Measurement & Verification of Energy & Water Savings; Achieved through the application of an ElectroCell System

February 21, 2020

Introduction

This document describes the methods for defining and verifying annual electrical and water savings resulting from the application of an ElectroCell System. The system is applied to the open-loop condenser water system and savings are realized in reductions in cooling plant energy and tower makeup water.

The savings definition and verification methods are consistent with guidelines and methods established by the International Performance Measurement and Verification Protocol (IPMVP) committee. The consolidation of energy use data is consistent with Air Conditioning Heating and Refrigeration Institute (AHRI) Integrated Part Load (IPLV) methods for categorizing chiller kW/ton data.




Energy Efficiency & Sustainability

Third Party Energy Savings Measurement & Validation for Utility

General M&V Methodology

Tonnage across chiller evaporator, concurrent kW of compressor, and concurrent condenser water temperature entering condenser bundle was evaluated before and after installation of Electrocell. Before and after kW/ton values for similar tons and condenser water temperatures were used to determine overall kW/ton reduction for each plant. kW/ton reduction was applied to chilled water load profiles (average ton versus month) to determine monthly kW reduction and kWh savings (see below for details). Final electric demand reductions and energy savings includes turning off sand pumps and netted against Electrocell electric load. Water savings was calculated based on a 3 gpm/ton, 1% evaporation rate, applying kW/ton demand reduction percentage that was determined for each plant.

Note: Weekly readings were taken of chiller performance and condenser water pumps through all seasons to confirm actual kWh reduction to baseline.



M&V Details - 70 NYA

This variable primary chilled water plant is not connected to Cimetrics, pre and post retrofit data was collected manually. Compressor kW was calculated from recorded amps, recorded voltage, and an assumed (constant) PF. Pre-retrofit tonnage was determined by measuring delta T across the evaporator and apply it to an assumed pump-speed of 48 Hz (based on observations and discussions with plant supervisor) using the chiller-specific table (below) to determine flow (gpm). Post-retrofit tonnage was determined by dT and measured and recorded Pump Hz using the below table. 70 NYA Chiller compressor monthly kW reductions and kWh savings were determined using a 70 NYA chilled water Tonnage versus real-time load profile curve developed by Kevin Gregory PE in 2012.

Cox TAB Report

70 NYA Chiller	40 Hz (TAB)	GPM/Hz
90101	1864	46.60
90102	1820	45.50
90103	1840	46.00
90104	1619	40.48
90105	1849	46.23

M&V Details - 55 NYA

This chilled water plant had data pulled from Cimetrics which provided significant amounts of pre and post retrofit data. Compressor kW was calculated from recorded amps, assumed 460 volts, and an assumed PF vs. load curve used to convert calculated KVA to kW at all loads. Tonnage was determined by measuring delta T across the evaporator at an assumed flow of 1900 gpm. 55 NYA kW reductions and kWh savings were determined using the same load profile curve, applying a 65% multiplier to account for reduced plant size.